

45 Creeper Hill Road Variance

1 message

Nancy Connors <connorsn@grafton-ma.gov>
To: Zoning Department <zba@grafton-ma.gov>

Mon, Dec 13, 2021 at 2:05 PM

If a private septic system is proposed you must be 10 feet from the tank and 20 feet to the leach field. If a private well is proposed you must be 25 feet from the well.

Thank you

Nancy Connors

Office Manager

Town of Grafton

Health Department

30 Providence Road

Grafton, MA 01519

Phone: 508-839-5335 X 1119

Fax: 508-839-8559

connorsn@grafton-ma.gov

www.grafton-ma.gov

Follow Us: [Facebook](#) |

When responding, please remember the Secretary of State considers e-mail a public record.

 **Consider the environment before printing this e-mail.**

PLEASE BE ADVISED, THE NEW HOURS AT THE MUNICIPAL CENTER EFFECTIVE 7/5/2021 ARE AS FOLLOWS:

MONDAY, WEDNESDAY, & THURSDAY 8:30-4:30

TUESDAY 8:30 - 7:00 P.M.

FRIDAY 8:30 - 1:00 P.M.

RECEIVED TOWN CLERK
GRAFTON, MA
2021 DEC 14 PM 2:14

RECEIVED

DEC 13 2021

Zoning